2242 West Harrison St., Suite 200, Chicago, IL 60612-3766

Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATAnalysis.com

Accreditations: IEPA ELAP 100445; ORELAP IL300001; AIHA-LAP, LLC 101160; NVLAP LabCode 101202-0

January 12, 2018

United Analytical Service, Inc. 1429 Centre Circle Drive Downers Grove, IL 60515 Telephone: (630) 691-8271

Fax:

(630) 691-1819

Analytical Report for STAT Work Order: 18010146 Revision 0

RE: 1798677-01, Olive Mary Stitt School, Room 191

Dear Thad Daniels:

STAT Analysis received 2 samples for the referenced project on 1/9/2018 2:00:00 PM. The analytical results are presented in the following report.

All analyses were performed in accordance with the requirements of 35 IAC Part 186 / NELAP standards. Analyses were performed in accordance with methods as referenced on the analytical report. Those analytical results expressed on a dry weight basis are also noted on the analytical report.

All analyses were performed within established holding time criteria, and all Quality Control criteria met EPA or laboratory specifications except when noted in the Case Narrative or Analytical Report. If required, an estimate of uncertainty for the analyses can be provided. A listing of accredited methods/parameters can also be provided.

Thank you for the opportunity to serve you and I look forward to working with you in the future. If you have any questions regarding the enclosed materials, please contact me at (312) 733-0551.

Sincerely,

Martin Kucan

Project Manager

Martin Vuenn

The information contained in this report and any attachments is confidential information intended only for the use of the individual or entities named above. The results of this report relate only to the samples tested. If you have received this report in error, please notify us immediately by phone. This report shall not be reproduced, except in its entirety, unless written approval has been obtained from the laboratory. This analytical report shall become property of the Customer upon payment in full. Otherwise, STAT will be under no obligation to support, defend or discuss the analytical report.

STAT Analysis Corporation

Date: January 12, 2018

Client:

United Analytical Service, Inc.

Project:

1798677-01, Olive Mary Stitt School, Room 191

Work Order Sample Summary

Work Order:

18010146 Revision 0

Lab Sample ID Client Sample ID

18010146-001A OM-FPW-191a R

18010146-002A OM-FPW-191b R

Tag Number Collection Date

1/9/2018 6:00:00 AM

1/9/2018 6:00:00 AM

Date Received

1/9/2018

1/9/2018

STAT Analysis Corporation

2242 West Harrison St., Suite 200, Chicago, IL 60612-3766

Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATanalysis.coi

Accreditation Numbers: IEPA ELAP 100445; ORELAP IL300001; AIHA-LAP, LLC 101160

Date Reported: January 12, 2018

ANALYTICAL RESULTS

Date Printed: January 12, 2018

Client: United Analytical Service, Inc.

Work Order: 18010146 Revision 0

Project: 1798677-01, Olive Mary Stitt School, Room 191

Client ID	Additional Info	Sample ID	Matrix	Lead Result Units Qualifier	Analyst	Date Analyzed	Analytical Method
OM-FPW-191a R		18010146-001A	Water	< 2.00 μg/L (ppb)	MDT	01/11/2018	E200.8R5.4
OM-FPW-191b R		18010146-002A	Water	< 2.00 μg/L (ppb)	MDT	01/11/2018	E200.8R5.4

S - Spike Recovery outside accepted recovery limits

R - RPD outside accepted recovery limits

E - Value above quantitation range

* - Non-accredited parameter

B - Analyte detected in the associated Method Blank

STAT Analysis Cotdoration
2242 W. Harrison, Suite 200, Chicago, Illinois 60612 Phone: (312) 733-0551 Fax: (312) 733-2386
e-mail address: STATinfo@STATAnalysis.com AIHA accredited 101160 NVLAP lab code 101202-0
CHAIN OF CUSTODY RECORD

2:001 3 Other: 2/18/120 **3** нехауаlеві Сһготиш Note: Not all turn around times are available for all analysis D. 3 Days: Drzt NIOZH 600 Date/Time: Date/Time: Date/Time: Date/Time: Date/Time: Date/Time: Dust NIOSH 500 2 Days: TCLP RCRA Metals LCLP Lead July ot 1 Day: Lead Wipe read Waste Water Page: .ead Drinking Water Relinquished by: Relinquished by: Relinquished by: 24 Hrs: fio2 bas. Received by: Received by: Received by: ring based basa TiA InsidmA bas. 8//61/1 Sample No. Laboratory OFFICE USE ONLY BELOW: 200 ž Lurn Around: 4 Hrs: Date Due: A House 50 Reported By (Initial/Date/Time/Method); Batch No. 9010146 Z X Yes: $(\text{Liters})|\text{Wiped}(\mathbf{ft}^2)|$ めっといかれ Area Checked by (Initial/Date): Samples Acceptable: QC by (Initial/Date): Rate Volume 3 Turn Around: **े** Comments: (mal) 01/00/10 Off L'ENVO 608.15 OLIVE AMAN STITSOMOL Time 5000 جَرَيْ ő Edgnids @ was 1.com ASS CSRO 5113 Damers lower 1 c * Nether Her Client Sample Number/Description:|Date Taken 8 1429 Contra Circle THAD DANGERS United Analytical 630.641.1319 1728-169-069 ÿ 10.2273611 10-6 (1886) اكا مصكا となるし DM-FAM-1916 R OM-FPW-191a R Project Manager: Project Location: Project Number: City, State, Zip: e-mail/Alt. Fax: Street Address: Project Name: P.O. Number: Comments: Phone:

STAT Analysis Corporation

Sample Receipt Checklist

Client Name UNITED ANALYTICAL	Date and Tim	e Received:	1/9/2018 2:00:00 PM	
Work Order Number 18010146		Received by:	JOK	
Checklist completed by: Signature Date Matrix: Carrier name	Client Delivered	Reviewed by:		1/9/18 Date
Shipping container/cooler in good condition?	Yes 🗹	No 🗌	Not Present	
·	Yes 🗆	No 🗆	Not Present ✓	
	Yes 🗆	No 🗆	Not Present ✓	
,	Yes 🗹	No 🗌		
	Yes 🗹	No 🗔		
	Yes 🗹	No 🗌		
	Yes 🔽	No 🗌		
	Yes 🗹	No 🗆		
	Yes 🗹	No 🗌		
All samples received within holding time?	res 🗹	No 🗆		
Container or Temp Blank temperature in compliance?	∕es ⊻	No 🗌	Temperatu	re Ambient °C
Water - VOA vials have zero headspace? No VOA vials submitt	ted 🔯	Yes 👑	No 🔣	
Water - Samples pH checked?	∕es 🗹	No 🗌	Checked by:	180e
Water - Samples properly preserved?	∕es 🗹	No 🗀	pH Adjusted?	No
Any No response must be detailed in the comments section below.				
Comments: Rush per Jue Frey verbal 1/	/11/18.			
Client / Person contacted: Date contacted:		Contac	sted by:	
Response:				

18010146

Laboratory ID	Client ID	CollectionDate	Units	Lead
18010146-001A	OM-FPW-191a R	1/9/2018	μg/L (ppb)	< 2.00
18010146-002A	OM-FPW-191b R	1/9/2018	$\mu g/L (ppb)$	< 2.00